

Project Name

Location

Prepared By



NUVO 62-1716-EM

7" SQ BLINK PRO EM BATT BACKUP

General

Status	Active
Voltage	120V
Finish	Bronze
Safety Listing	cULus - Certified; cULus - Listed
Location Rating	Dry
Each UPC	045923561245

Physical

Finish Family	Bronze
Material	Die-Cast Aluminum

Additional Information

Additional Information	90 Minute Battery Runtime; 24 Hour Recharge Time; Fixture not included; Battery should be changed approximately every 2 years
Installation Notes	Compatible with 3 in. and 4 in. J-Box & Pancake
For Use With	62-1716
Warranty	1-Year

Compliance

California Prop 65	Lead
UL Application	Low Frequency Emergency Lighting Inverter
RoHS Compliant	Yes
FCC Compliant	Yes
Canadian Standard ICES-005	Class A

Notes

[www] 05-12-2025 02:43:04